



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 3042376
Permit # 00893-2018UPG
Request Rec'd 07/16/2018
Amended Date
Approval Date 7/16/2018 DS
Permit Expires 1/16/2019

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Hy-Vee, Inc. 5820 Westown Parkway West Des Moines, IA 50266 Contact: John Brummit (515) 267-2800</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Hy Vee, Inc. 2110 E. Main Street Galesburg IL 61401 Contact: Brad Hopping (309) 342-2394</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired: (TK # 1, 3) - 14,000, (TK # 2) - 20,000, (TK # 4, 5) - 6,000*

(b) *Type of tanks:*

(c) *Type of piping: (TK # 5) Piping - Flexible Double Wall A.P.T. Poly Tech S175SC, (TK # 5) Piping - Other Piping Swing Joint, (TK # 5) Piping - Transition Sumps Bravo B-830 Series Single Wall*

(d) *Product to be stored in each tank: (TK # 1, 2, 3, 4) - Gasoline, (TK # 5) - Diesel Fuel*

(e) *Type of leak detection being used:*

Tank:

Piping: (TK # 1, 2, 3, 4, 5) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 Plus

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : Remove all (8) dispensers, remove (2) diesel dispenser sumps # 3,4 & # 13,14. Remove (2) gas dispenser sumps # 1,2 & # 15,16. Install (2) new APT poly dispenser sumps LMM-3617 # 1,2 & #15,16 install the existing APT P175-SC piping back into the (2) new dispenser sumps, Installing (2) new Bravo FRP B-833-SL transition sumps & new APT XP-175-SC DW piping from the new transition sumps into the new dispenser sumps 1,2 & 15,16 reusing the existing Sheer valves, flex connectors & Veeder Root TLS 350 sump sensors (794380-208) Installing (6) new 3' x 5' SS islands W / U-Shape guard post. Installing (4) new Gilbarco 700S NGO 3 product MPD's & (2) new Gilbarco 700S 4 product MPD's

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Seneca Companies, Inc.
4140 East 14th Street PO Box 3360
Des Moines, IA 50313

Contact Person: Keri Hankins
Phone: (816) 761-1270
Contractor Registration # IL598 Exp. 2/23/2020

Sincerely,

A handwritten signature in cursive script that reads "Daniel H. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File