



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

FOR OFFICE USE ONLY

Facility # 2014723
Permit # 00852-2018UPG
Request Rec'd 07/03/2018
Amended Date 07/17/2018 DS
Approval Date 7/9/2018 DS
Permit Expires 1/9/2019

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

| | |
|--|--|
| <p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Safa Enterprises, Inc. 4601 South Harlem Avenue Forest View, IL 60402 Contact: (847) 679-5398</p> | <p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Safa Enterprises, Inc. 4601 S. Harlem Ave. Forest View, IL 60402 Contact: Rosa (847) 679-5398</p> |
|--|--|

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 9, 10, 11) - 12,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 9, 10, 11) Piping - Fiberglass Single Wall Piping A.O. Smith, (TK # 9, 10, 11) Piping - Fiberglass Double Wall A.O. Smith, (TK # 9, 10, 11) Piping - Other submersible pump, (TK # 9, 10, 11) Piping - Submersible Sumps Bravo B-407-RB Single Wall*
- (d) Product to be stored in each tank: (TK # 9, 10, 11) - Gasoline*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 9, 10, 11) Spill Contain Device - Manhole Pre-manufactured EBW 705 Single Wall*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Replacement of partial vent lines due to the vent lines being inside the tank sumps

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:


Metro Environmental Contractors, Inc. dba Metro Tank & Pump

Contact Person: Warren Cherner

Company
1111 West Dundee Road
Wheeling IL 600903936

Phone: (847) 465-4000
Contractor Registration # IL102 Exp. 2/7/2020

Sincerely,

A handwritten signature in cursive script that reads "Daniel H. Starks". The signature is written in dark ink and is positioned above a thin horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File