



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 1011925
Permit # 00947-2018UPG
Request Rec'd 07/21/2018
Amended Date
Approval Date 7/23/2018 DS
Permit Expires 1/23/2019

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Beck Oil Company of Illinois 850 E. Thompson St. Princeton, IL 61356</p> <p>Contact: Bill Smith (815) 875-6451 Ext. 242</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Beck Oil Company 605 West Peru Street Princeton, IL 61356</p> <p>Contact: Bill Smith (815) 875-6451</p>
--	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired: (TK # 9) - 8,000, (TK # 10) - 4,000*

(b) *Type of tanks:*

(c) *Type of piping: (TK # 9, 10) Piping - Flexible Double Wall A.P.T. Poly Tech P175SC*

(d) *Product to be stored in each tank: (TK # 9) - Bio-Diesel, (TK # 10) - Diesel Fuel*

(e) *Type of leak detection being used:*

Tank:

Piping: (TK # 9, 10) Leak Detect - Piping - Electronic Pressurized Line Leak Detection Veeder Root TLS 450 Plus 8590 DPLLD

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.


(5) **SPECIAL CONTINGENCIES** : We would like to add 36" between the diesel islands- top of canopy removed with crane, west footing removed and replaced with new 36" west of existing, UDC will move 36" west, remove 15' pipe lengths between islands and replace with 18' lengths. expand canopy top 36" to west. **NOTE: Site has existing UDC's and sensors, which will be re-used.**

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Seneca Companies, Inc.
4140 East 14th Street PO Box 3360

Contact Person: Keri Hankins
Phone: (816) 761-1270

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File