



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Revised

FOR OFFICE USE ONLY

Facility # 7015249
Permit # 00826-2018REM
Request Rec'd 07/02/2018
Amended Date
Approval Date 7/2/2018 DS
Permit Expires 1/2/2019

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Baba Firma, LLC 902 N. Mulberry St. Mount Carmel, IL 62863 Contact: Danny Singh (618) 263-4931</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Jumpin' Jimmy's 902 Mulberry Street Mount Carmel, IL 62863 Contact: Danny Singh (618) 263-4931</p>
--	--

(3) REMOVAL OF TANKS:

(a) *Number and size of tanks being removed: (TK # 1) - 6,000, (TK # 2) - 8,000, (TK # 3) - 10,000, (TK # 10) - 2,000*

(b) *Description/location of piping being removed:*

(c) *Product to be stored in each tank: (TK # 1) - Diesel Fuel, (TK # 2, 3) - Gasoline, (TK # 10) - Unknown*

(d) *Reason of tanks being removed:*

(e) *If tank(s) is leaking, indicate IEMA incident number:*

(f) *Date each tank was last used: (TK # 1, 2, 3) - Unknown, (TK # 10) - 12/31/1973*

(4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) **SPECIAL CONTINGENCIES** : Added tank #10

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Jeff Guisewite, Inc.
16153 East 1100 Road
Mount Carmel, IL 62863

Contact Person: Jeff Guisewite
Phone: (618) 262-4933
Contractor Registration # IL497 Exp. 8/10/2018

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist
Division File