



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

<b>FOR OFFICE USE ONLY</b>
Facility # 2022888
Permit # 01019-2018UPG
Request Rec'd 07/31/2018
Amended Date
Approval Date 8/1/2018 DS
Permit Expires 2/1/2019

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>S &amp; J Gas, Inc. 15120 Arbor Drive Orland Park, IL 60567</p> <p>Contact: Stephen George (708) 299-3208</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Amoco 18572 203 W. Madison Street Oak Park, IL 60302</p> <p>Contact: Stephen George (708) 383-5178</p>
---	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 2, 3, 4) - 10,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 2, 3, 4) Piping - Fiberglass Single Wall Piping Ameron , (TK # 2, 3, 4) Piping - Shear Valves , (TK # 2, 3, 4) Piping - Flex Connector Steel*
- (d) Product to be stored in each tank: (TK # 2, 4) - Gasoline, (TK # 3) - Diesel Fuel*
- (e) Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.


(5) **SPECIAL CONTINGENCIES** : Demolsih dispenser island #7/8 and install a new containment sump. New single wall fiberglass piping from the existing single wall fiberglass piping will be run back into the new sump. A new island will be installed in the same location as previously located. **NOTE: A leak was found under dispenser 7/8 that caused line test to fail.**

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
B & K Equipment Company	Contact Person: Ed Angell

2939 175th Street  
Lansing, IL 60438

Phone: (708) 474-3344  
Contractor Registration # IL1207 Exp. 2/14/2020

Sincerely,

A handwritten signature in cursive script that reads "Daniel S. Starks". The signature is written in black ink and is positioned above a solid horizontal line.

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File