



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 4017320  
Permit # 01029-2018UPG  
Request Rec'd 08/02/2018  
Amended Date  
Approval Date 8/2/2018 DS  
Permit Expires 2/4/2019

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <b><u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Lanman Oil Company P.O. Box 108 Charleston, IL 61920</p> <p>Contact: Mike Lanman (217) 348-8020</p>	<p>(2) <b><u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Lambo Service 200 West Lincoln Charleston, IL 61920</p> <p>Contact: Mike Jones (217) 348-8020</p>
--	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired: (TK # 8, 9) - 12,000, (TK # 10) - 10,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 8, 9, 10) Piping - Flexible Double Wall A.P.T. Poly Tech S150SC, (TK # 8, 9, 10) Piping - Shear Valves, (TK # 8, 9, 10) Piping - Flex Connector Steel*
- (d) *Product to be stored in each tank: (TK # 8, 9) - Gasoline, (TK # 10) - Diesel Fuel*
- (e) *Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) *Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) *Spill containment devices, piping, and dispenser containmnt devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.


(5) **SPECIAL CONTINGENCIES** : Removing the (4) existing islands, UDC's & piping at the islands. Installing new APT LMM-3617 Poly dispenser sumps With OPW 10P-0152 sheer valves, new ss flex connectors, new APT XP-150SC double wall piping from dispenser sump 1/2 through dispenser sump 7/8. the existing piping from the tank sumps to dispenser sump 1/2 will remain. Pouring sloped concrete islands with U-Shape bumper post & installing the existing Gilbarco Dispensers. **NOTE: Sump sensors are existing and will be re-used per contractor**

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

Seneca Companies, Inc.  
4140 East 14th Street PO Box 3360  
Des Moines, IA 50313

Contact Person: Keri Hankins  
Phone: (816) 761-1270  
Contractor Registration # IL598 Exp. 2/23/2020

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File