



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 5001449  
Permit # 01094-2018UPG  
Request Rec'd 08/13/2018  
Amended Date  
Approval Date 8/13/2018 DS  
Permit Expires 2/14/2019

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <b><u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Ahlstrom Filtration Inc 1200 E Elm St Taylorville, IL 62568 Contact: Michael Chapman (217) 824-9611</p>	<p>(2) <b><u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Ahlstrom Filtration Inc 1200 E. Elm Street Taylorville, IL 62568 Contact: Michael Chapman (217) 824-9611</p>
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired: (TK # 5) - 20,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 5) Piping - Other Piping Swing Joint, (TK # 5) Piping - Required Other piping gasket gasket*
- (d) *Product to be stored in each tank: (TK # 5) - Methanol*
- (e) *Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) *Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) *Spill containment devices, piping, and dispenser containmnt devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES** : This tank failed a tank test, this permit is to repair any leaks on top of tank in sumps. There is flange gaskets and fittings in the sumps. We will be pressuring the tank with nitrogen at 3 PSI then soap all fittings and repair all bad fittings or gasket **NOTE: Contractor indicated that piping OR sumps will be affected, so I assume there will be work done to the sumps**

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

R. L. Hoener Company  
2923 Gardner Expressway P. O. Box 1086

Contact Person: Marty Jackson  
Phone: (217) 223-2190

Sincerely,

A handwritten signature in cursive script, reading "Daniel H. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File