



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY
Facility # 5046336
Permit # 01138-2018ENT
Request Rec'd 08/17/2018
Amended Date
Approval Date 8/20/2018 DS
Permit Expires 2/20/2019

Permit for HOTWORK/ ENTRY into Underground Storage Tank(s) for Petroleum and Hazardous Substances.

Permission to enter underground storage tank(s) is hereby granted. Such tank entry shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Triple L Ag Supply Inc. 10904 Rt 111 Medora, IL 62063</p> <p>Contact: Kenneth Loy (618) 535-5258</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Bucks Crossing 10904 Rt 111 Medora, IL 62063</p> <p>Contact: Kenneth Loy (618) 535-5258</p>
--	---

(3) ENTRY OF TANKS:

- (a) Number and size of tanks being entered: (TK # 2) - 4,000*
- (b) Type of tanks:*
- (c) Product to be stored in each tank: (TK # 2) - Gasoline*
- (d) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank entry has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling 2177851020.

(5) SPECIAL CONTINGENCIES : Tank relining lining inspection and entry permit work in reference to manways/manholes must abide by section 175.500. we will pump tank out, we will take pump and man-way out of sump.the tank will have a ventury put in, when safe the factory technicians will enter the tank, clean all sludge out.they will remove the man-way flange to gain access to the strap channel for repair. they will fix the leak in the sump and then replace the man-way flange . then air and test with soap. pump and manway will be put back into sump

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
<p>R. L. Hoener Company 2923 Gardner Expressway P. O. Box 1086 Quincy, IL 62305</p>	<p>Contact Person: Marty Jackson Phone: (217) 223-2190 Contractor Registration # IL2021 Exp. 5/22/2020</p>

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist
Division File