



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2005761
Permit # 01169-2018UPG
Request Rec'd 08/25/2018
Amended Date
Approval Date 8/27/2018 DS
Permit Expires 2/27/2019

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Round Lake Area School District 116 316 S. Rosedale Court Round Lake, IL 60073 Contact: Marc Weihofen (708) 546-5522	(2) FACILITY - name and address where tanks are located: Round Lake Area School District 116 811 N. Sunset Dr. Round Lake, IL 60073 Contact: Marc Weihofen (708) 546-5522
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 6) - 8,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 6) Piping - Fiberglass Single Wall Piping Ameron , (TK # 6) Piping - Valves Ball Valve, (TK # 6) Piping - Submersible Sumps OPW Fiberglass Single Wall, (TK # 6) Piping - Flex Connector Steel*
- (d) Product to be stored in each tank: (TK # 6) - Diesel Fuel*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 6) Spill Contain Device - Manhole Pre-manufactured EBW 705 Single Wall*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Diesel tank upgrade include:

- New OPW single wall fiberglass tank sump
- Cut back existing single wall FRP piping and then hook to existing and run into new tank sump
- Install new 2" flex connector
- Install new submersible pump
- Install new EBW 5 gallon below grade spill bucket

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Stenstrom Petroleum Services Group
2422 Center Street
Rockford, IL 61108

Contact Person: Robert Stenstrom
Phone: (815) 398-6250
Contractor Registration # IL1890 Exp. 4/12/2020

Sincerely,

A handwritten signature in cursive script that reads "Daniel H. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File