



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY
Facility # 2001839
Permit # 01204-2018UPG
Request Rec'd 08/28/2018
Amended Date
Approval Date 8/28/2018 DS
Permit Expires 2/28/2019

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Cook-Illinois Corp. 2100 Clearwater Drive Oak Brook, IL 60523 Contact: Todd Mancuso (708) 560-9840</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Kickert School Bus Line, Inc. 20575 Torrence Avenue Lynwood, IL 60411 Contact: Alex Sustek (708) 758-4740</p>
---	--

(3) UPGRADE OR REPAIR OF TANKS:


- (a) Number and size of tanks being upgraded or repaired: (TK # 5) - 12,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 5) Piping - Fiberglass Single Wall Piping Ameron , (TK # 5) Piping - Extractor Fitting Valves , (TK # 5) Piping - Valves none check valve, (TK # 5) Piping - Flex Connector Steel*
- (d) Product to be stored in each tank: (TK # 5) - Diesel Fuel*
- (e) Type of leak detection being used:*
Tank:
Piping:
- (f) Corrosion Protection being used:*
Tank:
Piping:
- (g) Spill containment devices, piping, and dispenser containmnt devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : Install a new singlewall rigid fiberglass, European suction line from tank #5 to pump sump position #2. **NOTE: If a dispenser sump in not existing on must be installed per 175.410 c) & d). European suction is not exempt from having a dispenser sump.**

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
<p>B & K Equipment Company 2939 175th Street</p>	<p>Contact Person: Ed Angell Phone: (708) 474-3344</p>

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File