



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 6026067
Permit # 01210-2018UPG
Request Rec'd 08/28/2018
Amended Date
Approval Date 8/29/2018 DS
Permit Expires 2/28/2019

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>QuikTrip Corporation 4705 South 129th East Avenue Tulsa, OK 74134</p> <p>Contact: Laura Thompson (918) 615-7865</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Quik Trip # 698 2809 Godfrey Road Godfrey, IL 62035</p> <p>Contact: Laura Thompson (918) 615-7658</p>
------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 2) - 12,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 2) Piping - Copper Single Wall Piping, (TK # 2) Piping - Shear Valves*
- (d) Product to be stored in each tank: (TK # 2) - Gasoline*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.
- (5) SPECIAL CONTINGENCIES** : "NOV ON 8/21/18-Failed line test for tank 1 RUL line running to dispenser 1/2." Upgrading and adding a Shear Valve from No Lead Tank #2, to Feed Dispenser #1/2, from an additional existing product line (used to be Mid-Grade Line Back 20 Years ago). That line runs all the way to Dispenser #1/2 currently, but is capped off because this site has (2) Unleaded tanks and Blending Dispensers. So the most cost effective way to fix the line under dispenser 1/2 is to Capp off the "bad line" to the dispenser and open up the line that's not being Used (Unleaded Line). The line that's not being used will now feed into Dispenser #1/2 with putting a shear valve on the line and feeding the Unleaded from Tank #2. to the Dispenser.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Neumayer Equipment Company, Inc.
5060 Arsenal Street
St. Louis, MO 63139

Contact Person: Jimmy Spiros
Phone: (314) 772-4501
Contractor Registration # IL1502 Exp. 3/26/2020

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File