



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2020554
Permit # 01234-2018UPG
Request Rec'd 09/04/2018
Amended Date
Approval Date 9/4/2018 DS
Permit Expires 3/5/2019

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Patten Industries, Inc. 635 W. Lake Street Elmhurst, IL 60126 Contact: Terry Flick (000) 000-0000	(2) <u>FACILITY</u> - name and address where tanks are located: Patten Industries, Inc. 635 W. Lake Street Elmhurst, IL 60126 Contact: Terry Flick (630) 279-4400
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 15) - 4,680, (TK # 16) - 930, (TK # 17, 19) - 2,340, (TK # 18) - 1,870, (TK # 20) - 932*
- (b) Type of tanks:*
- (c) Type of piping:*
- (d) Product to be stored in each tank: (TK # 15) - Diesel Fuel, (TK # 16, 18) - Transmission Oil, (TK # 17) - New Oil, (TK # 19) - Hydraulic Oil, (TK # 20) - Anti-Freeze*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping: (TK # 15, 16, 17, 18, 19, 20) Leak Detect - Piping - Interstitial Monitoring*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES** : Permitting to make piping sump sensors Non-Regulated sensors. Piping is European Safe Suction.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Beacon SSI, Inc.
2413 South 7th Avenue

Contact Person: Patrick Ferriter
Phone: (708) 917-2263

Sincerely,

A handwritten signature in cursive script, reading "Daniel H. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File