



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 6017334
Permit # 01283-2018UPG
Request Rec'd 09/10/2018
Amended Date
Approval Date 9/10/2018 DS
Permit Expires 3/12/2019

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Buck's, Inc. 7315 Mercy Road Omaha, NE 68124 Contact: Surinder Markanda (402) 558-9860	(2) <u>FACILITY</u> - name and address where tanks are located: Bucky's Express 1000 BeltLine Road Collinsville, IL 62234 Contact: Matt Pindell (402) 558-9860
--	--

(3) UPGRADE OR REPAIR OF TANKS:


- (a) *Number and size of tanks being upgraded or repaired: (TK # 7, 8) - 20,000, (TK # 9) - 12,000, (TK # 10) - 8,000*
 - (b) *Type of tanks:*
 - (c) *Type of piping:*
 - (d) *Product to be stored in each tank: (TK # 7, 8, 9) - Gasoline, (TK # 10) - Diesel Fuel*
 - (e) *Type of leak detection being used:*
 - Tank:*
 - Piping:*
 - (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
 - (g) *Spill containment devices, piping, and dispenser containment devices:*
 - (h) *Overfill prevention devices: (TK # 7, 8, 9, 10) Overfill Prev Device - Overfill Drop Tube Valve, (TK # 7, 8, 9, 10) Overfill Prev Device - Overfill Alarm*
 - (i) *Manway accessible at grade:*
- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.
- (5) **SPECIAL CONTINGENCIES** : Knocking out the Ball Floats for the current "Ball Float Vent Valve OPW 53" in order to make them Overfill Devices for all (4) Tanks. **NOTE: Site already has a TLS 350 overfill alarm in place**

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Neumayer Equipment Company, Inc.
5060 Arsenal Street

Contact Person: Jimmy Spiros
Phone: (314) 772-4501

Sincerely,

A handwritten signature in cursive script that reads "Daniel H. Starks". The signature is written in dark ink and is positioned above a thin horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File