



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY
Facility # 2020312
Permit # 01364-2018REM
Request Rec'd 09/19/2018
Amended Date
Approval Date 9/20/2018 DS
Permit Expires 3/20/2019

Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>LHD, Inc. 2450 The Strand Northbrook, IL 60062 Contact: Dong Han Lee (847) 602-3736</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>LHD, Inc. 812 Waukegan Rd Northbrook, IL 60062 Contact: Dong Hun Lee (847) 602-3736</p>
--	--

(3) REMOVAL OF PIPING:

- (a) Description/location of piping being removed:*
- (b) Which tank(s) are associated with the piping being removed: (TK # 1) - 12,000, (TK # 2, 3) - 10,000*
- (c) Reason of piping being removed:*
- (d) If piping is leaking, indicate IEMA incident number:*

(4) After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) SPECIAL CONTINGENCIES :

REMOVE EXISTING PRODUCT LINES ONLY FOR TANKS # 1,2,3.
EXISTING PRODUCT LINES OURSIDE SUBMERSIBLE CONTAINMENT ARE STEEL. **NOTE: Tanks are STIP3 single wall and have been out of service since 1/19/18, therefore if the work is not complete and tanks are not back in service fully by 1/09/19 the tanks MUST be removed per 175.810 d)**

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

<p>DRW Services, Inc. 600 East Joe Orr Road Chicago Heights, IL 60411</p>	<p>Contact Person: Douglas Harmon Phone: (708) 758-3222 Contractor Registration # IL194 Exp. 3/10/2020</p>
---	--

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist
Division File