



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 3005216
Permit # 01381-2018UPG
Request Rec'd 09/13/2018
Amended Date
Approval Date 9/24/2018 DS
Permit Expires 3/26/2019

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Walt's Service, Inc. 2827 18th Avenue Rock Island, IL 61201 Contact: Walter Schaecker (309) 786-4747	(2) FACILITY - name and address where tanks are located: Walt's Service, Inc. 2827 18th Avenue Rock Island, IL 61201 Contact: Walter Schaecker (309) 786-4747
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 3) - 6,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 3) Piping - Flexible Double Wall A.P.T. Poly Tech P175SC, (TK # 3) Piping - Single Wall Submersible (STP) Sump Franklin Fueling Systems 4736 Series Polyethylene*
- (d) *Product to be stored in each tank: (TK # 3) - Gasoline*
- (e) *Type of leak detection being used:*
 - Tank:*
 - Piping: (TK # 3) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Incon TSP ULS*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES** : Installation of APT STP sump on tank # 3 replacing existing, installation of new APT piping from new STP sump to the two fueling position nearest the tank. Addition of Udc sensors at the 2 dispensers impacted in the scope as well as replacement of the existing sensor in the tank STP sump.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Seneca Companies, Inc.

Contact Person: Keri Hankins

4140 East 14th Street PO Box 3360
Des Moines, IA 50313

Phone: (816) 761-1270
Contractor Registration # IL598 Exp. 2/23/2020

Sincerely,

A handwritten signature in cursive script, reading "Daniel H. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File