



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 1034566
Permit # 01391-2018UPG
Request Rec'd 08/27/2018
Amended Date
Approval Date 9/24/2018 DS
Permit Expires 3/26/2019

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Rockford Stop-N-Go, Inc. 2934 Fish Hatchery Road Madison, WI 53713 Contact: Andrew Bowman (608) 271-4433	(2) <u>FACILITY</u> - name and address where tanks are located: Stop-N-Go 1000 South 7th Street Rochelle, IL 610689309 Contact: Diana Johnson (608) 271-4433
--	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) Number and size of tanks being upgraded or repaired: (TK # 3) - 12,000

(b) Type of tanks:

(c) Type of piping: (TK # 3) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX, (TK # 3) Piping - Other submersible pump, (TK # 3) Piping - Shear Valves, (TK # 3) Piping - Flex Connector Steel, (TK # 3) Piping - Single Wall Submersible (STP) Sump Bravo B-407-TG

(d) Product to be stored in each tank: (TK # 3) - Diesel Fuel

(e) Type of leak detection being used:

Tank:

Piping: (TK # 3) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection FE Petro STP-MLD-D

(f) Corrosion Protection being used:

Tank:

Piping:

(g) Spill containment devices, piping, and dispenser containmnt devices:

(h) Overfill prevention devices:

(i) Manway accessible at grade:

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.


(5) SPECIAL CONTINGENCIES : Stop-N-Go is proposing the replacement of submersible pumps, submersible containment and associated piping runs on the existing tank number 3. Site has existing sump sensors

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Oil Equipment Company, Inc.
4701 Lien Road
Madison, WI 53704

Contact Person: Jerry Tigges
Phone: (608) 249-2881
Contractor Registration # IL1318 Exp. 10/29/2018

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File