



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**Amended**

**FOR OFFICE USE ONLY**

Facility # 2012588  
Permit # 00977-2018UPG  
Request Rec'd 07/26/2018  
Amended Date 09/26/2018 DS  
Approval Date 7/26/2018 DS  
Permit Expires 1/28/2019

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) <u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Loyola University Medical Center 2160 South 1st Avenue Building 201, Att: John Scanlon, Director, PP&amp;G Maywood, IL 60153</p> <p>Contact: Dave Niksic (708) 216-9182</p>	<p><b>(2) <u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Loyola University Medical Center 2160 So.1st Avenue Maywood, IL 60153</p> <p>Contact: Dave Niksic (708) 216-9503</p>
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

(a) *Number and size of tanks being upgraded or repaired: (TK # 2) - 4,000, (TK # 5) - 2,000, (TK # 6, 10, 11) - 2,500, (TK # 8) - 10,000, (TK # 9) - 5,400*

(b) *Type of tanks:*

(c) *Type of piping:*

(d) *Product to be stored in each tank: (TK # 2, 5, 8, 9, 10, 11) - Diesel Fuel, (TK # 6) - Gasoline*

(e) *Type of leak detection being used:*

*Tank:*

*Piping: (TK # 2, 5, 6, 8, 9, 10, 11) Leak Detect - Piping - European with No Test Req Suction, (TK # 2, 5, 6, 8, 10, 11) Leak Detect - Piping - Piping Sump Sensors Not Regulated*

(f) *Corrosion Protection being used:*

*Tank:*

*Piping:*

(g) *Spill containment devices, piping, and dispenser containmnt devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

Permitting to reprogram piping sump sensors as Non-regulated on a European Safe Suction System.

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Beacon SSI, Inc.  
2413 South 7th Avenue

Contact Person: Patrick Ferriter  
Phone: (708) 917-2263

Sincerely,

A handwritten signature in cursive script, reading "Daniel H. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File