



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

<p align="center">FOR OFFICE USE ONLY</p> <p>Facility # 3022824 Permit # 01409-2018UPG Request Rec'd 09/25/2018 Amended Date 09/26/2018 DS Approval Date 9/25/2018 DS Permit Expires 3/26/2019</p>

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Casey's Retail Company P.O. Box 3001 3305 SE Delaware Ave. Ankeny, IA 50021 Contact: Jill Reams-Widder (515) 965-6238</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Casey's General Store #1380 104 Route 122 Hopedale, IL 61747 Contact: Kelly Billington (515) 965-6238</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 7) - 15,000*
- (b) Type of tanks:*
- (c) Type of piping:*
- (d) Product to be stored in each tank: (TK # 7) - Gasoline*
- (e) Type of leak detection being used:*
Tank:
Piping:
- (f) Corrosion Protection being used:*
Tank:
Piping:
- (g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 7) Spill Contain Device - Single Wall Spill Bucket Franklin Fueling Systems Defender 705*
- (h) Overfill prevention devices: (TK # 7) Overfill Prev Device - Overfill Drop Tube Valve Franklin Fueling Systems 708 Defender Series*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Need to change style of droptube from coaxial to straight

<p>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</p> <p>Seneca Companies, Inc. 4140 East 14th Street PO Box 3360 Des Moines, IA 50313</p>	<p>Contact Person: Keri Hankins Phone: (816) 761-1270 Contractor Registration # IL598 Exp. 2/23/2020</p>
---	--

Sincerely,

Daniel H. Starks

Daniel Starks

cc: Storage Tank Safety Specialist
Division File