



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

<b>FOR OFFICE USE ONLY</b>
Facility # 6024332
Permit # 01450-2018UPG
Request Rec'd 10/01/2018
Amended Date
Approval Date 10/1/2018 DS
Permit Expires 4/2/2019

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>J.D. Streett &amp; Company, Inc. 144 Weldon Parkway Maryland Heights, MO 63043</p> <p>Contact: Darrell Meek (800) 678-6600</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Troy Citgo 437 Edwardsville Rd Box 136 Troy, IL 62294</p> <p>Contact: Darrell Meek (618) 667-8057</p>
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 1, 2, 3) - 10,000*
- (b) Type of tanks:*
- (c) Type of piping:*
- (d) Product to be stored in each tank: (TK # 1, 2, 3) - Gasoline*
- (e) Type of leak detection being used:*  
*Tank:*  
*Piping:*
- (f) Corrosion Protection being used:*  
*Tank:*  
*Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 1, 2, 3) Spill Contain Device - Double Wall Spill Bucket Franklin Fueling Systems Defender 705*
- (h) Overfill prevention devices: (TK # 1, 2, 3) Overfill Prev Device - Overfill Drop Tube Valve Franklin Fueling Systems 708 Defender Series*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
UPC Enterprises, LC d/b/a United Petroleum Service 4444 Union Blvd. St. Louis, MO 63115	Contact Person: Harvey Stokes Phone: (314) 241-3767 Contractor Registration # IL002402 Exp. 2/10/2020

---

Sincerely,

*Daniel H. Starks*

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File