



City of Chicago
 Department of Public Health
 333 South State Street, Room 200
 Chicago, IL 60604
 3127453152

Amended

<p>FOR OFFICE USE ONLY Facility # 2046690 Permit # 01431-2018REM Request Rec'd 09/27/2018 Amended Date 10/08/2018 Chi Approval Date 9/28/2018 Permit Expires 3/28/2019</p>

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity: University of Chicago 5323 S Harper Ct Chicago, IL 60615 Contact: Heather Sims (773) 702-9999</p>	<p>(2) FACILITY - name and address where tanks are located: South Campus Dorm Construction Site 1155 E 60th Street Chicago, IL 60637 Contact: Heather Sims (773) 702-9999</p>
--	--

(3) REMOVAL OF TANKS:

- (a) *Number and size of tanks being removed: (TK # 3, 4) - 146*
- (b) *Description/location of piping being removed:*
- (c) *Product to be stored in each tank: (TK # 3, 4) - #2 Fuel Oil*
- (d) *Reason of tanks being removed:*
- (e) *If tank(s) is leaking, indicate IEMA incident number:*
- (f) *Date each tank was last used: (TK # 3, 4) - 12/31/1973*


(4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) SPECIAL CONTINGENCIES :

Discovery of additional 146 gallon tank while excavating

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
<p>AQS Services Inc 443 South Clay Street Hinsdale, IL 60521</p>	<p>Contact Person: William Anthony Phone: (630) 789-3345 Contractor Registration # IL1913 Exp. 3/20/2020</p>

Sincerely,


 Chief Engineer-Storage Tank Section

Raul Valdivia

cc: Storage Tank Safety Specialist
 Division File