



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

FOR OFFICE USE ONLY

Facility # 3046674
Permit # 00963-2018INS
Request Rec'd 07/23/2018
Amended Date 10/09/2018 DS
Approval Date 7/24/2018 DS
Permit Expires 1/24/2019

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

| | |
|--|--|
| <p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Jerry Kaiser 919 Detroit Ct. Morton, IL 61550</p> <p>Contact: Jerry Kaiser (309) 266-9694</p> | <p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Tremont BP 120 Lake St. Tremont, IL 61568</p> <p>Contact: Jerry Kaiser (309) 266-9694</p> |
|--|--|

(3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed: (TK # 1) - 20,000, (TK # 2) - 8,000, (TK # 3) - 10,000*
- (b) Type of tank(s): (TK # 1, 2, 3) Tank - Fiberglass Double Wall Containment Solutions*
- (c) Type of piping: (TK # 1, 2, 3) Piping - Fiberglass Single Wall Piping Ameron Dualoy 3000L single wall fiberglass piping, (TK # 1, 2, 3) Piping - Flexible Double Wall A.P.T. Poly Tech P175SC, (TK # 1, 2, 3) Piping - Extractor Fitting Valves, (TK # 1, 2, 3) Piping - Shear Valves, (TK # 1, 2, 3) Piping - Single Wall Submersible (STP) Sump Containment Solutions Fiberglass*
- (d) Product to be stored in each tank: (TK # 1, 2) - Gasoline, (TK # 3) - Diesel Fuel*
- (e) Type of leak detection being used:*
 - Tank: (TK # 1, 2, 3) Leak Detect - Tank - Automatic Tank Gauging Incon TS 550 with SCALD, (TK # 1, 2, 3) Leak Detect - Tank - Interstitial Monitoring Incon TSP HFS*
 - Piping: (TK # 1, 2, 3) Leak Detect - Piping - Electronic Pressurized Line Leak Detection Incon TSLS 500, (TK # 1, 2, 3) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Incon TSP ULS*
- (f) Corrosion Protection being used:*
 - Tank: (TK # 1, 2, 3) Corrosion Prot - Tank - Fiberglass Non-Corrosive*
 - Piping: (TK # 1, 2, 3) Corrosion Prot - Piping - Flexible Non-Corrosive*
- (g) Spill containment devices, piping and dispenser containment devices: (TK # 1, 2, 3) Spill Contain Device - Single Wall Spill Bucket EBW 705*
- (h) Overfill prevention devices: (TK # 1, 2, 3) Overfill Prev Device - Overfill Drop Tube Valve OPW 71SO-4000*

- (4)** The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov by calling (217)785-1020.

- (5) GENERAL REQUIREMENTS** : There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion

protection.

(6) SPECIAL CONTINGENCIES :

I want to change tank id to match the site and the size was wrong on the application for one of the tanks.

I want to amend the 6000 gallon tank 3 to a 8000 gallon and make it tank 2. So I will have at this site


tank 1 20,000 gallon gas, tank 2 8000 gallon gas, tank 3 10,000 gallon Diesel

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

All Line Equipment, Inc.
5519 Skyline Drive, PO Box 5257
Quincy, IL 62305

Contact Person: Steve Disselhorst
Phone: (217) 224-9725
Contractor Registration # IL002319 Exp. 12/23/2019

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File