



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

FOR OFFICE USE ONLY Facility # 4015246 Permit # 01547-2018UPG Request Rec'd 10/15/2018 Amended Date 10/15/2018 DS Approval Date 10/15/2018 DS Permit Expires 4/16/2019

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Mac's Convenience Stores, LLC 550 Warrenville Rd. Suite 400 Lisle, IL 60532 Contact: Charlene Troyer (331) 251-7343</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Circle K #1338 314 South Line Road Tuscola, IL 61953 Contact: Richard Reis (812) 379-9227</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 6) - 10,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 6) Piping - Ball Valves, (TK # 6) Piping - Single Wall Submersible (STP) Sump OPW Flexworks Poly Sump*
- (d) Product to be stored in each tank: (TK # 6) - Gasoline*
- (e) Type of leak detection being used:*
Tank:
Piping: (TK # 6) Leak Detect - Piping - Electronic Pressurized Line Leak Detection Red Jacket Pro Max
- (f) Corrosion Protection being used:*
Tank:
Piping:
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

- **Only doing this work to Tank # 6***
- **Only doing Work to Tank # 6***

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
<p>Neumayer Equipment Company, Inc. 5060 Arsenal Street St. Louis, MO 63139</p>	<p>Contact Person: Jimmy Spiros Phone: (314) 772-4501</p>

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File