



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 1015661  
Permit # 01632-2018UPG  
Request Rec'd 10/25/2018  
Amended Date  
Approval Date 10/25/2018 DS  
Permit Expires 4/25/2019

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) <u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Johnson Oil Company 1305 12th Avenue Rock Falls, IL 61071  Contact: Kathy Peugh (815) 625-6380</p>	<p><b>(2) <u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Expresslane #4 220 1st Avenue Rock Falls, IL 61071  Contact: Heather Thayer (815) 626-4084</p>
---	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 1, 2) - 8,200*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 1, 2) Piping - Flexible Double Wall A.P.T. Poly Tech P175SC, (TK # 1, 2) Piping - Single Wall Submersible (STP) Sump Franklin Fueling Systems 4542 Series Polyethylene*
- (d) Product to be stored in each tank: (TK # 1, 2) - Gasoline*
- (e) Type of leak detection being used:*
  - Tank:*
  - Piping: (TK # 2) Leak Detect - Piping - Non-Discriminating Sump Sensor Interstitial Monitoring Franklin Fueling Systems, (TK # 2) Leak Detect - Piping - Siphon Bar NOTE: Sensor must shut down submersible upon detection of a leak per 175.640 a) 1)*
- (f) Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES** : permit to siphon tank # 1 & 2 together. stp sumps to be installed at both tanks for siphon line tank entry

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Illowa Enterprises, Inc.  
2703 4th Avenue

Contact Person: Rob Vyncke  
Phone: (309) 762-1729

Sincerely,

A handwritten signature in cursive script, reading "Daniel H. Starks", is written over a horizontal line.

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File