



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2013812
Permit # 01668-2018UPG
Request Rec'd 10/30/2018
Amended Date
Approval Date 10/30/2018 DS
Permit Expires 4/30/2019

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: SMRR, Inc. 8 E. Main Street Cary, IL 60013 Contact: Sam Makim (847) 462-1590	(2) FACILITY - name and address where tanks are located: Cary Marathon 8 E. Main Street Cary, IL 60013 Contact: Mohammad Sharif (847) 462-1590
---	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) Number and size of tanks being upgraded or repaired: (TK # 1, 2, 3) - 8,000

(b) Type of tanks:

(c) Type of piping:

(d) Product to be stored in each tank: (TK # 1, 3) - Gasoline, (TK # 2) - Diesel Fuel

(e) Type of leak detection being used:

Tank:

Piping:

(f) Corrosion Protection being used:

Tank:

Piping:

(g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 2) Spill Contain Device - Single Wall Spill Bucket OPW 1C-2115 DEVR, (TK # 3) Spill Contain Device - Single Wall Spill Bucket OPW 1C-2100C-DEVR

(h) Overfill prevention devices: (TK # 1, 3) Overfill Prev Device - Overfill Drop Tube Valve OPW 71SO-400C, (TK # 2) Overfill Prev Device - Overfill Drop Tube Valve OPW 71SO-410C

(i) Manway accessible at grade:

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : All ball floats failed testing and will be disabled to add overfill prevention drop tubes. Tanks #2 #3 spill containers will be changed because the non-overfill drop tubes were not removable from the fill riser pipes.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

B & K Equipment Company

Contact Person: Ed Angell

2939 175th Street
Lansing, IL 60438

Phone: (708) 474-3344
Contractor Registration # IL1207 Exp. 2/14/2020

Sincerely,

A handwritten signature in cursive script, reading "Daniel H. Starks", written in black ink on a white background. The signature is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File