



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**Extended**

**FOR OFFICE USE ONLY**

Facility # 2020312  
Permit # 01364-2018REM  
Request Rec'd 09/19/2018  
Amended Date  
Approval Date 9/20/2018 DS  
Permit Expires 9/20/2019

**Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances.**

Permission to remove underground storage tank piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <b><u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>LHD, Inc. 2450 The Strand Northbrook, IL 60062  Contact: Dong Han Lee (847) 602-3736</p>	<p>(2) <b><u>FACILITY</u></b> - name and address where tanks are located:</p> <p>LHD, Inc. 812 Waukegan Rd Northbrook, IL 60062  Contact: Dong Hun Lee (847) 602-3736</p>
---	---

(3) **REMOVAL OF PIPING:**

- (a) *Description/location of piping being removed:*
- (b) *Which tank(s) are associated with the piping being removed: (TK # 1) - 12,000, (TK # 2, 3) - 10,000*
- (c) *Reason of piping being removed:*
- (d) *If piping is leaking, indicate IEMA incident number:*

- (4) After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) **SPECIAL CONTINGENCIES :**

REMOVE EXISTING PRODUCT LINES ONLY FOR TANKS # 1,2,3.  
EXISTING PRODUCT LINES OUTSIDE SUBMERSIBLE CONTAINMENT ARE STEEL. **NOTE: Tanks are STIP3 single wall and have been out of service since 1/19/18, therefore if the work is not complete and tanks are not back in service fully by 1/09/19 the tanks MUST be removed per 175.810 d)**

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

DRW Services, Inc.  
600 East Joe Orr Road  
Chicago Heights, IL 60411

Contact Person: Douglas Harmon  
Phone: (708) 758-3222  
Contractor Registration # IL194 Exp. 3/10/2020

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File