



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**Amended**

**FOR OFFICE USE ONLY**

Facility # 1015661  
Permit # 01632-2018UPG  
Request Rec'd 10/25/2018  
Amended Date 11/13/2018 DS  
Approval Date 10/25/2018 DS  
Permit Expires 4/25/2019

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) <u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Johnson Oil Company 1305 12th Avenue Rock Falls, IL 61071  Contact: Kathy Peugh (815) 625-6380</p>	<p><b>(2) <u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Expresslane #4 220 1st Avenue Rock Falls, IL 61071  Contact: Heather Thayer (815) 626-4084</p>
---	---

**(3) UPGRADE OR REPAIR OF TANKS:**

*(a) Number and size of tanks being upgraded or repaired: (TK # 1, 2) - 8,200*

*(b) Type of tanks:*

*(c) Type of piping: (TK # 1, 2) Piping - Other Steel Riser*

*(d) Product to be stored in each tank: (TK # 1, 2) - Gasoline*

*(e) Type of leak detection being used:*

*Tank:*

*Piping:*

*(f) Corrosion Protection being used:*

*Tank:*

*Piping:*

*(g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 1, 2) Spill Contain Device - Single Wall Spill Bucket EBW 705*

*(h) Overfill prevention devices: (TK # 1) Overfill Prev Device - Overfill Alarm EBW Auto-Stik Jr.*

*(i) Manway accessible at grade:*

**(4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

original permit was to siphon tanks 1 & 2 together. After uncovering top of tanks, not enough room for proposed siphon sumps. Now under separate permit propose to partially abandon product line for tank # 2. Want to change this permit to add 2 new fills, ( tank 1&2) and install 3 new risers. 2 fill risers for tank 1&2 and one riser for probe on tank 2. Also removed overfill drop tube on tank 1 as station has overfill alarm.

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**


Illowa Enterprises, Inc.

Contact Person: Rob Vyncke

2703 4th Avenue  
Moline, IL 61265

Phone: (309) 762-1729  
Contractor Registration # IL981 Exp. 5/1/2020

Sincerely,

A handwritten signature in cursive script, reading "Daniel H. Starks", is written over a horizontal line.

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File