



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 4014346
Permit # 01783-2018UPG
Request Rec'd 11/15/2018
Amended Date
Approval Date 11/15/2018 DS
Permit Expires 5/15/2019

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Tuscola Properties P.O. Box 108 Charleston, IL 61920</p> <p>Contact: Michael Lanman (217) 348-8020</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Lambo's 1000 East Southline Road Tuscola, IL 61953</p> <p>Contact: Bryan Trail (217) 348-8020</p>
---	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) Number and size of tanks being upgraded or repaired: (TK # 17) - 20,000

(b) Type of tanks:

(c) Type of piping: (TK # 17) Piping - Flexible Double Wall A.P.T. Poly Tech S175SC, (TK # 17) Piping - Shear Valves, (TK # 17) Piping - Flex Connector Steel

(d) Product to be stored in each tank: (TK # 17) - Diesel Fuel

(e) Type of leak detection being used:

Tank:

Piping: (TK # 17) Leak Detect - Piping - Non-Discriminating Sump Sensor Interstitial Monitoring Veeder Root NOTE: Sensor must shut down the submersible upon detection of a leak per 175.640 a) 1)

(f) Corrosion Protection being used:

Tank:

Piping:

(g) Spill containment devices, piping, and dispenser containmnt devices:

(h) Overfill prevention devices:

(i) Manway accessible at grade:

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.


(5) SPECIAL CONTINGENCIES : Adding a 18' x 24' addition to the existing 24' x 42' canopy, (1) SS 4' x 8' bowtie island w/ APT LMM-3617 Encore Poly dispenser sump w/ OPW 10P-0152 sheer valves, steel flex connectors Veeder Root TLS 450 Non discriminating sump sensor (749380-208) , Partial DW APT XP-175SC product piping & 42" poured concrete cylindrical bollards. Gilbarco Encore Diesel/DEF/Satelite dispenser combo

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Seneca Companies, Inc.
4140 East 14th Street PO Box 3360
Des Moines, IA 50313

Contact Person: Keri Hankins
Phone: (816) 761-1270
Contractor Registration # IL598 Exp. 2/23/2020

Sincerely,



Daniel G. Starks

Daniel Starks

cc: Storage Tank Safety Specialist
Division File