



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY
Facility # 1039141
Permit # 01839-2018UPG
Request Rec'd 11/27/2018
Amended Date
Approval Date 11/27/2018 DS
Permit Expires 5/29/2019

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>A.B.E., Inc. d/b/a The Station 1865 IL Rt. 84 Thomson, IL 61285 Contact: Lisa Johnson (815) 259-2705</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>The Station 1865 IL Rt. 84 Thomson, IL 61285 Contact: Lisa Johnson (815) 259-2705</p>
--	---

(3) UPGRADE OR REPAIR OF TANKS:


- (a) Number and size of tanks being upgraded or repaired: (TK # 1) - 12,000, (TK # 3) - 8,000*
- (b) Type of tanks:*
- (c) Type of piping:*
- (d) Product to be stored in each tank: (TK # 1, 3) - Gasoline - Regular*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 1, 3) Spill Contain Device - Single Wall Spill Bucket EBW 715*
- (h) Overfill prevention devices: (TK # 1, 3) Overfill Prev Device - Overfill Drop Tube Valve Franklin Fueling Systems 708 Defender Series*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES : Replacing the tank #1 and the tank #3 spill and overfill

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
PIPECO, Inc. 610 29TH ST Bettendorf, IA 52722	Contact Person: Debbie Rindler Phone: (563) 344-0700 Contractor Registration # IL2034 Exp. 9/28/2020

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File