



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 6011105  
Permit # 01876-2018UPG  
Request Rec'd 12/03/2018  
Amended Date  
Approval Date 12/3/2018 DS  
Permit Expires 6/4/2019

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

|                                                                                                                                                                                                                                           |                                                                                                                                                                                                                   |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <p><b>(1) <u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Moto, Inc.<br/>721 W. Main Street P.O. Box 0122<br/>Belleville, IL 622220122</p> <p>Contact: Rob Whittington (618) 233-6754 Ext. 106</p> | <p><b>(2) <u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Village Motomart<br/>721 North Bluff Road<br/>Collinsville, IL 62234</p> <p>Contact: Rob Whittington (618) 233-6754 Ext. 106</p> |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 7, 8) - 15,000, (TK # 9) - 5,000, (TK # 10) - 10,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 7, 8, 9, 10) Piping - Flexible Double Wall A.P.T. Poly Tech S150SC, (TK # 7, 8, 9, 10) Piping - Ball Valves, (TK # 7, 8, 9, 10) Piping - Shear Valves, (TK # 7, 8, 9, 10) Piping - Flex Connector Steel*
- (d) Product to be stored in each tank: (TK # 7, 8) - Gasoline, (TK # 9) - Gasoline - Premium, (TK # 10) - Diesel Fuel*
- (e) Type of leak detection being used:*
  - Tank:*
  - Piping: (TK # 7, 8, 9, 10) Leak Detect - Piping - Electronic Pressurized Line Leak Detection Incon TSLS 500, (TK # 7, 8, 9, 10) Leak Detect - Piping - Non-Discriminating Sump Sensor Interstitial Monitoring Incon*
- (f) Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.


- (5) **SPECIAL CONTINGENCIES** : Adding 4 Wayne Ovation dispensers and associated APT product piping to the existing system as shown on the drawing. The APT Poly dispenser sumps will be set at grade. Incon sump sensors will be installed. The UL and Premium piping will connect to the existing system at the tank sumps as shown and the diesel will connect at an existing dispenser sump as shown. The existing Incon LS 500 electronic line leak detection will remian. **NOTE: Tanks 1-6 will be removed under permit 01577-2018REM**

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

UPC Enterprises, LC d/b/a United Petroleum Service  
4444 Union Blvd.  
St. Louis, MO 63115

Contact Person: Harvey Stokes  
Phone: (314) 241-3767  
Contractor Registration # IL002402 Exp. 2/10/2020

Sincerely,

A handwritten signature in cursive script, reading "Daniel G. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File