



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY
Facility # 1013419
Permit # 01879-2018UPG
Request Rec'd 12/04/2018
Amended Date
Approval Date 12/4/2018 DS
Permit Expires 6/4/2019

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Fayez Mizyed 14032 Route 72 East Davis Junction, IL 61020 Contact: Fayez Mizyed (815) 761-5720</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Corner Amoco 14032 Route 72 East Davis Junction, IL 61020 Contact: Nidal Mizyed (815) 761-5720</p>
----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 1) - 2,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 1) Piping - Other submersible pump, (TK # 1) Piping - Ball Valves, (TK # 1) Piping - Single Wall Submersible (STP) Sump Franklin Fueling Systems 4736 Series Polyethylene*
- (d) *Product to be stored in each tank: (TK # 1) - Racing Fuel*
- (e) *Type of leak detection being used:*
 - Tank:*
 - Piping: (TK # 1) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection FE Petro STP-MLD-D*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containmnt devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.


(5) **SPECIAL CONTINGENCIES** : Replacing the existing Red Jacket submersible with new FE Petro submersible. Installing new APT poly sump. Installing new 2" ball valve. Replacing old Red Jacket mechanical leak detector with new FE Petro mechanical leak detector. Existing fiberglass single wall piping to remain. Precision test will be performed after hydro test, and prior to final.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
Howard Lee & Sons Inc.	Contact Person: Vicky Buhl

4093 Perryville Road PO Box 446
Cherry Valley, IL 61016

Phone: (815) 332-4966
Contractor Registration # IL456 Exp. 3/20/2020

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File