



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY
Facility # 1039679
Permit # 01907-2018UPG
Request Rec'd 11/27/2018
Amended Date
Approval Date 12/7/2018 FS
Permit Expires 6/7/2019

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>VP Oil, Inc. 1515 Seward Street Schaumburg IL 60193</p> <p>Contact: Paul Dandona (815) 505-5767</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Lakewood Mini - Mart 4742 East 2750 Road Sandwich, IL 60548</p> <p>Contact: Ahmad Muhammad (815) 498-4351</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 2) - 8,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 2) Piping - Other Steel Riser*
- (d) Product to be stored in each tank: (TK # 2) - Gasoline*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : All violations on current NOV complied or closed for tanks 1 and 2. A violation for tank 3 has been referred to legal. Permit approved to allow work to comply new violation for tank 2 to replace spill bucket, overfill drop tube valve and possibly the riser.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
<p>B & K Equipment Company 2939 175th Street Lansing IL 60438</p>	<p>Contact Person: Ed Angell Phone: (708) 474-3344 Contractor Registration # IL1207 Exp. 2/14/2020</p>

Sincerely,

□
Fred Schneller

cc: Storage Tank Safety Specialist
Division File