



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 2018605  
Permit # 01911-2018UPG  
Request Rec'd 12/05/2018  
Amended Date  
Approval Date 12/10/2018 DS  
Permit Expires 6/11/2019

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) <u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>HPT TA Properties, LLC 24601 Center Ridge Road Westlake, OH 44145  Contact: Rob Porges (440) 808-7268</p>	<p><b>(2) <u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Morris Travel Center 21 Romines Drive Morris, IL 60450  Contact: Missy DiDomizio (815) 942-5690</p>
--	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 3) - 12,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 3) Piping - Single Wall Submersible (STP) Sump OPW Fiberglass*
- (d) Product to be stored in each tank: (TK # 3) - Diesel Fuel*
- (e) Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

**NOTE: Setbacks will be met, per contractor. Setback section of application was filled out incorrectly.**

- Saw-cut a 12' x 12' section of concrete and dipsose of clean concrete.
- Excavation of tank sump to tank top. Sockpile pea gravel onsite to be reused.
- Cut back product and syphon lines.


- Cut back electrical conduits.
- Remove tank sump and dispose.
- Installation of one (1) OPW fiberglass tank sump.
- Installation of two (2) tank adaptors.
- Installation of new entry boots.
- Rework electrical conduits.
- Rework Ameron fiberglass syphon lines.
- Attempt to reuse Veeder-Root cable for sump sensor.
- Backfill, set new manhole, pin and pour concrete using a 9-bag mix.
- Perform third party tank test.

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Northern Indiana Mechanical, Inc.  
3311 E. 15th Avenue  
Gary, IN 46403

Contact Person: Mike Kiest  
Phone: (219) 963-1640  
Contractor Registration # IL292 Exp. 3/25/2019

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist  
Division File