



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2039149
Permit # 01964-2018UPG
Request Rec'd 12/12/2018
Amended Date
Approval Date 12/12/2018 DS
Permit Expires 6/12/2019

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: FedEx Freight, Inc. 2200 Forward Drive, DC: 2219 Harrison, AR 72601 Contact: Brenden Rose (870) 365-4087	(2) <u>FACILITY</u> - name and address where tanks are located: FedEx Freight, Inc.-CGT 470 E. Joe Orr Road Chicago Heights, IL 604118565 Contact: Robert Baumgardner (870) 365-4087
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 1, 2) - 20,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 1, 2) Piping - Steel Single Wall Piping, (TK # 1, 2) Piping - Other submersible pump, (TK # 1, 2) Piping - Flex Connector Steel*
- (d) Product to be stored in each tank: (TK # 1, 2) - Diesel Fuel*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Replacing existing submerged pump with new model. All re-fitting of piping is in an existing sump.

There are two independant tank and piping systems on site. Both STP's will be replaced, one per day on consecutive days.


(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Contact Person: Ed Angell

B & K Equipment Company
2939 175th Street
Lansing, IL 60438

Phone: (708) 474-3344
Contractor Registration # IL1207 Exp. 2/14/2020

Sincerely,

A handwritten signature in cursive script that reads "Daniel H. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File