



City of Chicago
Department of Public Health
 333 South State Street, Room 200
 Chicago, IL 60604
 3127453152

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to (the contractor or subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Underground Storage Tanks. The time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Chicago Public Schools 1 North Dearborn, Suite 950 Chicago, IL 60602</p> <p>Contact: Robert Christlieb (312) 965-6434</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Hanson Park Field House 5411 W. Fullerton Ave. Chicago, IL 60639</p> <p>Contact: Robert Christlieb (312) 965-6434</p>
---	---

(3) REMOVAL OF TANKS:

- (a) Number and size of tanks being removed: (TK # 1) - 2,000*
- (b) Description/location of piping being removed:*
- (c) Product to be stored in each tank: (TK # 1) - Heating Oil*
- (d) Reason of tanks being removed:*
- (e) If tank(s) is leaking, indicate IEMA incident number:*
- (f) Date each tank was last used: (TK # 1) - 12/31/1973*

(4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This may be done by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of petroleum products at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Regulations.

(5) SPECIAL CONTINGENCIES :

Expose top of tank. Look in tank for remaining liquids. Pump liquids from tank. Monitor gas inside tank. Clean sides of tank. Remove tank and clean then dispose of offsite.

Site Plans

<p>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</p>	
<p>The Lighthouse Companies 3120 Cottonwood Court Highland Park, IL 60035</p>	<p>Contact Person: Alan Levine Phone: (224) 619-4307 Contractor Registration # IL002409 Exp. 6/19/2011</p>

Sincerely,

Shelly Bradley

cc: Storage Tank Safety Specialist
Division File