



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 4013187
Permit # 02016-2018UPG
Request Rec'd 12/21/2018
Amended Date
Approval Date 12/24/2018 DS
Permit Expires 6/25/2019

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>KB Sullivan, Inc. 140 Hearthstone Drive Bartlett, IL 60103</p> <p>Contact: Kamlesh Patel (863) 370-6500</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>KB Sullivan, Inc. 105 West Jackson Sullivan, IL 61951</p> <p>Contact: Hardikkumar Patel (217) 728-2296</p>
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 7, 8) - 10,000, (TK # 9) - 8,000, (TK # 10, 11) - 5,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 7, 8, 9, 10, 11) Piping - Flexible Double Wall Total Containment Enviroflex non-corrosive*
- (d) Product to be stored in each tank: (TK # 7, 11) - Gasoline - Regular, (TK # 8) - Gasoline - Premium, (TK # 9) - Diesel Fuel, (TK # 10) - Kerosene*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping: (TK # 7, 8, 9, 10, 11) Leak Detect - Piping - Piping Sump Sensors Not Regulated*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.


- (5) **SPECIAL CONTINGENCIES** : Requesting upgrade permit to get Total Containemnt piping with Chase and interstitiial monitoring to single wall piping and non regulated sensor as per conervation with Fred Schneller.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Pemco Service Company, Inc.
1040 East Second Street

Contact Person: William "Butch" VonDrehle
Phone: (815) 265-7364

Sincerely,

A handwritten signature in cursive script, reading "Daniel H. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File