



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

FOR OFFICE USE ONLY

Facility # 2022859
Permit # 02010-2018UPG
Request Rec'd 12/20/2018
Amended Date 12/28/2018 SB
Approval Date 12/24/2018 DS
Permit Expires 6/25/2019

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Graham C-Stores Co. 33978 N. US Hwy 45 P.O Box 89 Gages Lake, IL 600300089 Contact: Mike Graham (847) 254-7605</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Wilmette BP 901 Green Bay Road Wilmette, IL 60091 Contact: Binu George (847) 853-7451 Ext. 15</p>
--	---

(3) UPGRADE OR REPAIR OF TANKS:

(a) Number and size of tanks being upgraded or repaired: (TK # 3) - 12,000

(b) Type of tanks:

(c) Type of piping:

(d) Product to be stored in each tank: (TK # 3) - Gasoline

(e) Type of leak detection being used:

Tank:

Piping:

(f) Corrosion Protection being used:

Tank:

Piping:

(g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 3) Spill Contain Device - Single Wall Spill Bucket Franklin Fueling Systems Defender 705

(h) Overfill prevention devices: (TK # 3) Overfill Prev Device - Overfill Drop Tube Valve OPW 71SO-400C

(i) Manway accessible at grade:

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Spill Bucket is only a Defender Series single wall -5-Gallon unit. Part # 705545011CI-GKT.

SNOW RING BROKEN ON EXISTING EBW 15 GALLON GRADE LEVEL SPILL BUCKET
REPLACE WITH NEW FRANKLINE FUELINF DEFENDER SERIES SINGLE WALL 5-GALLON GRADE LEVEL
SPILL BUCKET.
REPLACE OVERFILL DROP TUBE ASSEMBLY WITH NEW OPW 71SO-400C SERIES AS EXISTING WITH
NEW SPILL BUCKET WILL NOT MEET THE SHUTOFF REQUIREMENTS.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

DRW Services, Inc.
600 East Joe Orr Road
Chicago Heights, IL 60411

Contact Person: Douglas Harmon
Phone: (708) 758-3222
Contractor Registration # IL194 Exp. 3/10/2020

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File