



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)524-7605

| |
|-----------------------------|
| FOR OFFICE USE ONLY |
| Facility # 2-014573 |
| Permit # 02030-2008UPG |
| Request Rec'd 12/10/2008 |
| Amended Date |
| Approval Date 12/10/2008 DS |
| Permit Expires 6/10/2009 |

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

| | |
|--|---|
| <p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Speedway SuperAmerica, LLC P.O. Box 1500 Springfield, OH 45501-1500 Contact: Lance Cunningham (317) 872-3200 Ext.</p> | <p>(2) FACILITY - name and address where tanks are located: Speedway 7540 948 Farnsworth Avenue Aurora, Kane Co., IL Contact: Kathleen Griener</p> |
|--|---|

(3) UPGRADE OR REPAIR OF TANKS:

(a) Number and size of tanks being upgraded or repaired: (TK # 1, 2, 4) - 10,000 gallons, (TK # 3) - 12,000 gallons

(b) Type of tanks:

(c) Type of piping:

(d) Product to be stored in each tank: (TK # 1, 2, 3) - Gasoline, (TK # 4) - Diesel Fuel

(e) Type of leak detection being used:

Tank: (TK # 1, 2, 3, 4) - (Installing) Automatic Tank Gauging Veeder Root TLS 350

Piping: (TK # 1, 2, 3, 4) - (Installing) Electronic Pressurized Line Leak Detection Veeder Root TLS 350

(f) Corrosion Protection being used:

Tank:

Piping:

(g) Spill containment devices:

(h) Overfill prevention devices:

(i) Manway accessible at grade:

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

| |
|---|
| <p>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</p> <p align="right">Contact Person: Stephen M Kryl Phone: (708) 795-9052 Contractor Registration # IL-002332 Exp.</p> |
|---|

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist -
 Fire Department -
 Office Coordinator -
 Division File
 (Rev. - 1/98)