



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-032549
Permit # 01994-2008UPG
Request Rec'd 11/19/2008
Amended Date
Approval Date 12/4/2008 DS
Permit Expires 6/4/2009

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: HPTTA Properties, LLC 24601 Center Ridge Road Westlake, OH 44145 Contact: Jim Shenker (440) 808-7368	(2) FACILITY - name and address where tanks are located: Travel Center of America #030 16650 Russell Road Russell, Lake Co., IL Contact: Pat Ryan (847) 395-5580
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 1, 2, 3, 4, 5) - 20,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 1, 2, 3, 4, 5) - (Installing) Fiberglass Double Wall A.O. Smith product piping from tanks to dispenser transition sumps, and also for siphon lines.
- (d) *Product to be stored in each tank:* (TK # 1, 2, 3, 4, 5) - Diesel Fuel
- (e) *Type of leak detection being used:*
Tank:
Piping: (TK # 1, 2, 3, 4, 5) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 in all tank sumps, in "H" valve containment sump, dispenser transition sumps, and also in all dispenser sumps if they don't already exist from previous piping installation, (TK # 2, 4) - (Installing) Mechanical Pressurized Line Leak Detection Red Jacket FX1DV to be installed at Big Blow diaphragm valves at tanks 2 & 4, all other piping to be monitored from previously existing PLLD.
- (f) *Corrosion Protection being used:*
Tank:
Piping:
- (g) *Spill containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Contact Person: Jack Meek Phone: (630) 860-9500 Contractor Registration # IL-881 Exp.
--

Sincerely,

Daniel Starks

