



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY
Facility # 6-012103
Permit # 00144-2013UPG
Request Rec'd 02/26/2013
Amended Date
Approval Date 2/27/2013 DS
Permit Expires 8/27/2013

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Gateway FS, Inc. 221 East Pine Street Red Bud, IL 62278 Contact: Greg Birchler (618) 282-3454	(2) FACILITY - name and address where tanks are located: Gateway FS, Inc. 615 South St Louis Street Sparta, Randolph Co., IL Contact: Dan Rieckenberg (618) 967-3227
---	---

(3) UPGRADE OR REPAIR OF TANKS:

(a) **Number and size of tanks being upgraded or repaired:** (TK # 1, 5) - 10,000 gallons, (TK # 6) - 5,000 gallons, (TK # 7) - 8,000 gallons

(b) **Type of tanks:**

(c) **Type of piping:** (TK # 1, 5, 6, 7) - (Installing) Partial Fiberglass Single Wall Piping Ameron to accomodate new sumps at new dispenser island and also at tanks #5 & 7, where the piping will join just outside of the new submersible sumps, (TK # 1, 6) - (Installing) Dispenser Sumps containment FRP under new dispenser island that is being installed, (TK # 5, 7) - (Installing) Submersible Sumps containment FRP

(d) **Product to be stored in each tank:** (TK # 1, 5) - Gasoline, (TK # 6) - E-85, (TK # 7) - Diesel Fuel

(e) **Type of leak detection being used:**

Tank:

Piping:

(f) **Corrosion Protection being used:**

Tank:

Piping: (TK # 1, 5, 6, 7) - (Installing) Fiberglass Non-Corrosive

(g) **Spill containment devices, piping, and dispenser containment devices:**

(h) **Overfill prevention devices:**

(i) **Manway accessible at grade:**

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Cape Girardeau, MO 63703	Contact Person: Billy Thorne Phone: (573) 335-5529 Contractor Registration # Exp.
---	---

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 9/10)