



**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL**  
**Division of Technical Services**  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)524-7605

**Amended**

<b>FOR OFFICE USE ONLY</b> Facility # 3-011091 Permit # 01200-2008INS Request Rec'd 07/21/2008 Amended Date 10/30/2008 Approval Date 7/22/2008 JC Permit Expires 1/22/2009
--

**Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Moline City Of          619 16Th St          Moline, IL 61265</p> <p>Contact: George Stevens (309) 797-0751</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Municipal Ser Garage          3635 4Th Ave          Moline, Rock Island Co., IL</p> <p>Contact: George Stevens (309) 797-0751</p>
---	---

**(3) INSTALLATION OF TANKS:**

- (a) **Number and size of tanks being installed:** (TK # 6) - 10,000 gallons
- (b) **Type of tanks:** (TK # 6) - (Installing) Fiberglass Double Wall XERXES
- (c) **Type of piping:** (TK # 6) - (Installing) Flexible Double Wall A.P.T. Poly Tech P175 SC
- (d) **Product to be stored in each tank:** (TK # 6) - E-85
- (e) **Type of leak detection being used:**
  - Tank:** (TK # 6) - (Installing) Automatic Tank Gauging Veeder Root TLS 350 Plus , (TK # 6) - (Installing) Interstitial Monitoring Veeder Root TLS 350 Plus
  - Piping:** (TK # 6) - (Installing) Electronic Pressurized Line Leak Detection Veeder Root TLS 350 Plus , (TK # 6) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 Plus in the sumbersible sump and dispenser sump
- (f) **Corrosion Protection being used:**
  - Tank:** (TK # 6) - (Installing) Fiberglass Non-Corrosive
  - Piping:** (TK # 6) - (Installing) Non-Corrosive Flexible Non-Corrosive
- (g) **Spill containment devices:** (TK # 6) - (Installing) Manhole Pre-manufactured EBW 705
- (h) **Overfill prevention devices:**

**(4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020.**

**(5) GENERAL REQUIREMENTS:**

**(6) SPECIAL CONTINGENCIES:**

<p><b>(7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u></b></p>	<p>Contact Person:          Phone: (309) 762-1729          Contractor Registration # IL-981 Exp.</p>
---	--

Sincerely,

*Daniel G. Starks*

cc: Storage Tank Safety Specialist -  
 Fire Department -  
 Office Coordinator -  
 Division File  
 (Rev. - 1/98)