



**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL**  
**Division of Technical Services**  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)524-7605

<b>FOR OFFICE USE ONLY</b>
Facility # 6-033229
Permit # 01686-2008UPG
Request Rec'd 09/29/2008
Amended Date
Approval Date 9/30/2008 DS
Permit Expires 3/30/2009

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Moto Mart, Inc.        721 West Main Street, P. O. Box 122        Belleville, IL 62222-0122</p> <p>Contact: Joe Hooten (618) 233-6756 Ext.</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>O'Fallon Moto Mart        8401 US Highway 50, US 50 &amp; Route 158        Lebanon, St. Clair Co., IL</p> <p>Contact: Joe Hooten (618) 628-1477</p>
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) **Number and size of tanks being upgraded or repaired:** (TK # 1, 2) - 20,000 gallons
- (b) **Type of tanks:**
- (c) **Type of piping:** (TK # 1, 2) - (Installing) Flexible Double Wall OPW Pisces flexible product piping that will also be contained within new secondary chase piping to supply the three new islands
- (d) **Product to be stored in each tank:** (TK # 1, 2) - Gasoline
- (e) **Type of leak detection being used:**
  - Tank:** (TK # 1, 2) - (Installing) Automatic Tank Gauging Incon TS-550
  - Piping:** (TK # 1, 2) - (Installing) Electronic Pressurized Line Leak Detection Incon TS-LLD, (TK # 1, 2) - (Installing) Interstitial Piping Sump Sensores TSP-ULS in submersible sumps and dispenser sumps
- (f) **Corrosion Protection being used:**
  - Tank:**
  - Piping:**
- (g) **Spill containment devices:**
- (h) **Overfill prevention devices:**
- (i) **Manway accessible at grade:**

**(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020.**

**(5) SPECIAL CONTINGENCIES:** Changed the piping sump sensor model on 10/1/08

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b></p>	<p>Contact Person: Gregory K Spiros          Phone: (314) 644-6000</p> <p>Contractor Registration #    Exp.</p>
--	---

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist -  
 Fire Department -  
 Office Coordinator -  
 Division File  
 (Rev. - 1/98)