



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)524-7605

FOR OFFICE USE ONLY
Facility # 2-043821
Permit # 01687-2008INS
Request Rec'd 09/29/2008
Amended Date
Approval Date 9/30/2008 DS
Permit Expires 3/30/2009

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Harjit Sahi 1217 E. Cambridge Dr. Schererville, IL 46375</p> <p>Contact:</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Raceco 450 Cicero Avenue University Park, Will Co., IL</p> <p>Contact:</p>
--	--

(3) INSTALLATION OF TANKS:

- (a) **Number and size of tanks being installed:** (TK # 5) - 6,000 gallons, (TK # 6) - 4,000 gallons, (TK # 7, 8) - 20,000 gallons, (TK # 9, 10) - 10,000 gallons
- (b) **Type of tanks:** (TK # 5, 6, 7, 8, 9, 10) - (Installing) Fiberglass Double Wall Containment Solutions
- (c) **Type of piping:** (TK # 5, 6, 7, 8, 9, 10) - (Installing) Fiberglass Double Wall Ameron Dualoy 3000/LCX
- (d) **Product to be stored in each tank:** (TK # 5) - Diesel Fuel, (TK # 6) - Racing Fuel, (TK # 7, 8, 9, 10) - Gasoline
- (e) **Type of leak detection being used:**
 - Tank:** (TK # 5, 6, 7, 8, 9, 10) - (Installing) Automatic Tank Gauging Veeder Root TLS350
 - Piping:** (TK # 5, 6, 7, 8, 9, 10) - (Installing) Mechanical Pressurized Line Leak Detection Red Jacket FX1 , (TK # 5, 6, 7, 8, 9, 10) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS350 in all dispenser sumps and submersible sumps
- (f) **Corrosion Protection being used:**
 - Tank:** (TK # 5, 6, 7, 8, 9, 10) - (Installing) Fiberglass Non-Corrosive
 - Piping:** (TK # 5, 6, 7, 8, 9, 10) - (Installing) Fiberglass Non-Corrosive
- (g) **Spill containment devices:** (TK # 5, 6, 7, 8, 9, 10) - (Installing) Manhole Pre-manufactured OPW 1-2100
- (h) **Overfill prevention devices:**

(4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

(5) GENERAL REQUIREMENTS:

(6) SPECIAL CONTINGENCIES:

<p>(7) PERSON, FIRM OR COMPANY PERFORMING WORK:</p>	<p>Contact Person: Phone: (708) 516-0879</p> <p>Contractor Registration # IL-914 Exp.</p>
--	--

Sincerely,

cc: Storage Tank Safety Specialist -
 Fire Department -
 Office Coordinator -
 Division File
 (Rev. - 1/98)