



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Technical Services  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)524-7605

FOR OFFICE USE ONLY  
Facility # 5-007415  
Permit # 01511-2008INS  
Request Rec'd 08/28/2008  
Amended Date  
Approval Date 9/2/2008 JC  
Permit Expires 3/2/2009

**Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  Joseph F. Boente Sons, Inc. 543 West Main Street, P.O. Box 288 Carlinville, IL 62626  Contact: David Boente (217) 854-3164	<b>(2) FACILITY</b> - name and address where tanks are located:  Greenfield Shell Rt 67 South Greenfield, Greene Co., IL  Contact: Boente Dave (217) 854-3164
---	---

**(3) INSTALLATION OF TANKS:**

- (a) Number and size of tanks being installed:** (TK # 6) - 8,000 gallons, (TK # 7) - 4,000 gallons
- (b) Type of tanks:** (TK # 6, 7) - (Installing) XERXES double wall fiberglass
- (c) Type of piping:** (TK # 6, 7) - Existing single wall fiberglass from tanks 1 & 2 will be hooked up to these new tanks and re-used (tanks 1 & 2 are being removed under permit #01481-2008REM).
- (d) Product to be stored in each tank:** (TK # 6, 7) - Gasoline
- (e) Type of leak detection being used:**
  - Tank:** (TK # 6, 7) - (Installing) Incon TS 750 interstitial tank sensor, (TK # 6, 7) - (Installing) Incon TS 750 automatic tank gauge
  - Piping:** (TK # 6, 7) - Existing line leak detector from tank systems 1 & 2 will be re-used for these new tanks
- (f) Corrosion Protection being used:**
  - Tank:** (TK # 6, 7) - (Installing) Fiberglass
  - Piping:** (TK # 6, 7) - Existing fiberglass
- (g) Spill containment devices:**
- (h) Overfill prevention devices:**

- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020.**

**(5) GENERAL REQUIREMENTS:**

- (6) SPECIAL CONTINGENCIES: Some equipment from tanks 1 & 2 will be re-used for these two new tanks. Tanks 1 & 2 are being removed under permit #01481-2008REM.**

<b>(7) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>          Contact Person: Phone: (217) 787-6081  Contractor Registration # IL-1949 Exp.
---

Sincerely,

cc: Storage Tank Safety Specialist -  
Fire Department -  
Office Coordinator -  
Division File  
(Rev. - 1/98)