

OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Division of Technical Services

1035 Stevenson Drive Springfield, Illinois 62703-4259 (217)524-7605

Amended

FOR OFFICE USE ONLY

Facility # 6-016407 Permit # 00912-2008INS Request Rec'd 06/05/2008

Amended Date 09/02/2008

Approval Date 6/5/2008 JC Permit Expires 12/5/2008

<u>Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.</u>

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE**.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:	(2) <u>FACILITY</u> - name and address where tanks are located:
Clinton County Oil Company, Inc. P. O. Box 155 Breese, IL 62230	C C Food Mart 1221 12th Street Carlyle, Clinton Co., IL
Contact: Gene Bickl (618) 526-7570	Contact: Dale Wade (618) 526-7291

(3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed: (TK # 6) 15,000 gallons, (TK # 7) 12,000 gallons, (TK # 8) 4,000 gallons
- (b) Type of tanks: (TK # 6, 7, 8) (Installing) Containment Solutions double wall fiberglass
- (c) Type of piping: (TK # 6, 7, 8) (Installing) Ameron Dualoy 3000/LCX double wall fiberglass
- (d) Product to be stored in each tank: (TK # 6, 8) Gasoline, (TK # 7) Diesel Fuel
- (e) Type of leak detection being used:

Tank: (TK # 6, 7, 8) - (Installing) Veeder Root **TLS350** automatic tank gauge (existing console and probes from the old tank system will be re-used, (TK # 6, 7, 8) - (Installing) Veeder Root **TLS 350** interstitial tank sensor

Piping: (TK # 6, 7, 8) - (Installing) Veeder Root **TLS350** interstitial piping sump sensors at all submersible sumps and all dispenser sumps, (TK # 6, 7, 8) - (Installing) Veeder Root **TLS350** electronic line leak detector

(f) Corrosion Protection being used:

Tank: (TK # 6, 7, 8) - (Installing) Fiberglass **Piping:** (TK # 6, 7, 8) - (Installing) Fiberglass

- (g) Spill containment devices:
- (h) Overfill prevention devices:
- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.
- (5) GENERAL REQUIREMENTS:
- (6) SPECIAL CONTINGENCIES:

(1)	ľ	Ľ	k	1)(J.	N	,	ľ	1	К	A)	/1	(J	К	U	L	J.	V	Ш	ľ	Α	ď	٧	Y	١.	ľ	H	ŀ	U	H)	U	К	J	VI.	П	N	G	١	W	U	ŀ	KI	K	•
•	٠.	_	_																																												_	

Contact Person: Harvey Stokes

Phone:

James J Coffey

Contractor Registration # IL-246 Exp. 05/28/2010

Sincerely,

cc: Storage Tank Safety Specialist - Fire Department -

Office Coordinator -Division File

(Rev. - 1/98)