



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-017427
Permit # 01509-2008INS
Request Rec'd 08/28/2008
Amended Date
Approval Date 9/2/2008 JC
Permit Expires 3/2/2009

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: MKM Oil, Inc. P.O. Box 317 Gardner, IL 62424 Contact: Rick Marketti (815) 237-0100	(2) FACILITY - name and address where tanks are located: Braidwood Amoco 105 N. Front Street, Corner of Rt. 53 & 113 Braidwood, Will Co., IL Contact: Francis Kavanaugh
--	--

(3) INSTALLATION OF TANKS:

- (a) **Number and size of tanks being installed:** (TK # 8) - 20,000 gallons
- (b) **Type of tanks:** (TK # 8) - (Installing) Containment Solutions double wall fiberglass
- (c) **Type of piping:** (TK # 8) - (Installing) A.P.T. Poly Tech P200SC double wall flexible. One of the piping runs will go from the tank to the three dispenser row that is closest to Rt 113 (also, this pipe will hook into an existing line at the middle dispenser of this row, and will go to the last dispenser). At the middle dispenser of this row, the new line will also branch off and go to a new, future use, E-85 dispenser (this dispenser will become a blending type dispenser in the future that will blend the unleaded fuel from tank #8 with the alcohol fuel from tank #6, consequently creating E-85). The other piping run will go to the three dispenser row that is closer to the building.
- (d) **Product to be stored in each tank:** (TK # 8) - Gasoline
- (e) **Type of leak detection being used:**
Tank: (TK # 8) - (Installing) Veeder Root TLS 350 interstitial tank sensor, (TK # 8) - (Installing) Veeder Root TLS350 automatic tank gauge
Piping: (TK # 8) - (Installing) Veeder Root TLS350 electronic line leak detector, (TK # 8) - (Installing) Veeder Root TLS350 interstitial piping sump sensors at all submersible sumps and all dispenser sumps (the dispenser sump sensors may also be installed through permit #01510-2008UPG).
- (f) **Corrosion Protection being used:**
Tank: (TK # 8) - (Installing) Fiberglass
Piping: (TK # 8) - (Installing) Non-corrosive flexible
- (g) **Spill containment devices:**
- (h) **Overfill prevention devices:**

- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

(5) GENERAL REQUIREMENTS:

(6) SPECIAL CONTINGENCIES:

(7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u> Contact Person: Phone: (815) 265-7364 Contractor Registration # IL-1224 Exp.
--

Sincerely,

