



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 7-013245
Permit # 01490-2008FLX
Request Rec'd 08/29/2008
Amended Date
Approval Date 8/29/2008 JC
Permit Expires 2/28/2009

Permit for UPGRADE or REPAIR of FLEX CONNECTOR for existing Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair flex connector(s) is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for flex connector of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Fill Up Mart, Inc. 111 Washington Cairo, IL 62914 Contact: Phillip Hodges (618) 734-1491	(2) FACILITY - name and address where tanks are located: Fill Up Mart, Inc. 49 Cheekwood Lane Ullin, Pulaski Co., IL Contact: Phillip Hodges
--	---

(3) UPGRADE OR REPAIR OF FLEX CONNECTORS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 3) - 6,000 gallons
- (b) *Type of flex connector(s):* (TK # 3) - Existing steel flex connectors
- (c) *Product stored in each tank:* (TK # 3) - Diesel Fuel
- (d) *Corrosion Protection being installed with flex connector(s):* (TK # 3) - (Installing) Sacrificial anodes cathodic protection at the submersible sump only.

- (4) The owner must notify this Office when completion of flex connector upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for flex connector to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES:** This permit may have to be amended due to the fact that the manager of this station does not know for sure which tank this work is being done for. The contractor states the manager "thinks" it is for the "diesel" tank, but is "unsure"; consequently, if it turns out this work is for one of the other tanks, this permit will have to be amended to reflect the correction.

<u>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</u> Compliance Testing & Technology, Inc. 1142 North Adam Mason, IL 62443	Contact Person: Mark Yates Phone: 402-850-4510 Contractor Registration # Exp.
---	---

Sincerely,



cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 1/98)