



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

Amended

FOR OFFICE USE ONLY
Facility # 3-003309
Permit # 01264-2008INS
Request Rec'd 07/29/2008
Amended Date 08/19/2008
Approval Date 7/29/2008 JC
Permit Expires 1/29/2009

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Rock Island Co Public Works Dept 851 W 10Th Ave Milan, IL 61264 Contact: Lang Gary (309) 787-4668	(2) FACILITY - name and address where tanks are located: Rock Island Co-Pulbic Works Dept 851 W. 10th Ave. Milan, Rock Island Co., IL Contact: Lange Gary E (309) 787-4668
-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

(3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed:* (TK # 4) - 2,000 gallons
- (b) Type of tanks:* (TK # 4) - (Installing) Glasteel II double wall composite (replacing tank #1).
- (c) Type of piping:* (TK # 4) - **(Installing) Ameron single wall fiberglass product piping (European suction).**
- (d) Product to be stored in each tank:* (TK # 4) - Gasoline
- (e) Type of leak detection being used:*
 - Tank:** (TK # 4) - (Installing) EBW Auto Stik LS-30A interstitial tank sensor, (TK # 4) - (Installing) EBW Auto-Stik Jr. automatic tank gauge
 - Piping:** (TK # 4) - **(Installing) European Suction**
- (f) Corrosion Protection being used:*
 - Tank:** (TK # 4) - (Installing) Composite
 - Piping:** (TK # 4) - (Installing) Fiberglass
- (g) Spill containment devices:*
- (h) Overfill prevention devices:*

- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.**

(5) GENERAL REQUIREMENTS:

(6) SPECIAL CONTINGENCIES:

(7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u> Contact Person: Rob Vyncke Phone: Contractor Registration # IL-981 Exp. 04/25/2010

Sincerely,



cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 1/98)