



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

Amended

FOR OFFICE USE ONLY

Facility # 3-009225
Permit # 01377-2008UPG
Request Rec'd 08/07/2008
Amended Date 08/18/2008
Approval Date 8/13/2008 JC
Permit Expires 2/13/2009

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

Table with 2 columns: (1) OWNER OF TANKS - Corporation, partnership, or other business entity; (2) FACILITY - name and address where tanks are located. Includes contact information for Dana Robinson and Marvin Kading.

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 2) - 10,000 gallons, (TK # 3, 4) - 15,000 gallons, (TK # 5, 6, 7, 8, 9) - 20,000 gallons
(b) Type of tanks:
(c) Type of piping: (TK # 6, 7, 8, 9) - Existing fiberglass secondary containment chase piping to remain, (TK # 6, 7, 8, 9) - (Installing) OPW Pisces SP-20 single wall fiberglass primary product piping through the existing chase piping, to replace the existing primary run from the submersible sump to the load out rack sump only.
(d) Product to be stored in each tank: (TK # 2, 5, 6, 7) - Diesel Fuel, (TK # 3) - Kerosene, (TK # 4) - Heating Oil, (TK # 8, 9) - Gasoline
(e) Type of leak detection being used:
Tank:
Piping: (TK # 2, 3, 4, 5, 6, 7, 8, 9) - (Installing) FE Petro STP - MLD - HC mechanical line leak detector, (TK # 6, 7, 8, 9) - Existing interstitial monitoring at the submersible sump only, (TK # 6, 7, 8, 9) - (Installing) Veeder Root TLS350 interstitial piping sump sensors at the bulk load out rack sump for tanks 6,7,8,9 only.
(f) Corrosion Protection being used:
Tank:
Piping: (TK # 6, 7, 8, 9) - (Installing) Fiberglass product piping. Existing fiberglass chase piping will remain.
(g) Spill containment devices:
(h) Overfill prevention devices:
(i) Manway accessible at grade:

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Contact Person: Chris Epkins, Phone: (309) 347-1819, Contractor Registration # Exp.

Sincerely,

Handwritten signature of Jim Coffey

Jim Coffey

