



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)524-7605

| |
|----------------------------|
| <u>FOR OFFICE USE ONLY</u> |
| Facility # 2-010590 |
| Permit # 01380-2008REM |
| Request Rec'd 06/09/2008 |
| Amended Date |
| Approval Date 8/14/2008 JC |
| Permit Expires 2/14/2009 |

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

| | |
|--|--|
| <p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Cook Co. Dept. Facilities Management 69 W. Washington Street, 30th Floor Chicago, IL 60608</p> <p>Contact: Jim D'Amico</p> | <p>(2) FACILITY - name and address where tanks are located:</p> <p>Markham Court House 16501 S. Kedzie Ave. Markham, Cook Co., IL</p> <p>Contact: Richard Saunders (708) 865-4853</p> |
|--|--|

(3) REMOVAL OF TANKS:

- (a) *Number and size of tanks being removed:* (TK # 1) - 14,000 gallons
- (b) *Product stored in each tank:* (TK # 1) - Gasoline
- (c) *Reason of tanks being removed:*
- (d) *If tank(s) is leaking, indicate IEMA incident number:*
- (e) *Date each tank was last used:* (TK # 1) - 11/19/2004

(4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form This form can be obtained at www.state.il.us/osfm or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 170.640 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) SPECIAL CONTINGENCIES:

| | |
|--|---|
| <p>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</p> | |
| <p>Tecnica Environmental Services, Inc. 1612 West Fulton Street</p> | <p>Contact Person: Phone: Contractor Registration # Exp.</p> |

Sincerely,

cc: Storage Tank Safety Specialist -
 Fire Department -
 Office Coordinator -
 Division File
 (Rev. - 6/07)