



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-022701
Permit # 01366-2008INS
Request Rec'd 08/08/2008
Amended Date
Approval Date 8/12/2008 JC
Permit Expires 2/12/2009

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Amoco Research Center(F-3/EHS) 150 West Warrenville Road Naperville, IL 60563 Contact: James L Saylor (630) 420-4874	(2) FACILITY - name and address where tanks are located: BP Naperville Campus 150 West Warrenville Road,P.O. Box 3011 Naperville, Du Page Co., IL Contact: James Saylor (630) 420-4874
--	---

(3) INSTALLATION OF TANKS:

- (a) **Number and size of tanks being installed:** (TK # 113, 116) - 4,000 gallons, (TK # 114, 115) - 10,000 gallons, (TK # 117, 118, 119, 120, 121, 122, 123, 124) - 6,000 gallons (These tanks comprise a total of six compartment tanks).
- (b) **Type of tanks:** (TK # 113, 114, 115, 116, 117, 118, 119, 120, 121, 122, 123, 124) - (Installing) Containment Solutions double wall fiberglass brine filled
- (c) **Type of piping:** (TK # 113, 114, 115, 116, 117, 118, 119, 120, 121, 122, 123, 124) - (Installing) A.O. Smith double wall fiberglass (This includes the underground portions of the remote fill lines. The underground fiberglass fill lines will connect to above ground portions of existing steel remote fill lines).
- (d) **Product to be stored in each tank:** (TK # 113, 114, 115, 118, 119, 120, 121, 122, 123, 124) - Gasoline, (TK # 116, 117) - Diesel Fuel
- (e) **Type of leak detection being used:**
Tank: (TK # 113, 114, 115, 116, 117, 118, 119, 120, 121, 122, 123, 124) - (Installing) Incon TS 5000 automatic tank gauge with SCALD, (TK # 113, 114, 115, 116, 117, 118, 119, 120, 121, 122, 123, 124) - (Installing) Incon TSP - HIS Brite Interstitial hydrostatic tank sensor
Piping: (TK # 113, 114, 115, 116, 117, 118, 119, 120, 121, 122, 123, 124) - (Installing) Incon TSP - DDS Brite Sensor Interstitial piping sump sensors to be located at all submersible sumps, all dispenser sumps, and at lower end of remote fill line sumps, (TK # 113, 114, 115, 116, 117, 118, 119, 120, 121, 122, 123, 124) - (Installing) Incon TSLS 500 electronic line leak detector
- (f) **Corrosion Protection being used:**
Tank: (TK # 113, 114, 115, 116, 117, 118, 119, 120, 121, 122, 123, 124) - (Installing) Fiberglass
Piping: (TK # 113, 114, 115, 116, 117, 118, 119, 120, 121, 122, 123, 124) - (Installing) Fiberglass
- (g) **Spill containment devices:**
- (h) **Overfill prevention devices:**

- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

(5) GENERAL REQUIREMENTS:

(6) SPECIAL CONTINGENCIES:

(7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u> Contact Person: Jim Gaszynski Phone: (630) 530-9880 Contractor Registration # IL-1733 Exp.
--

Sincerely,

James J. Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 1/98)